



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5126BL0564

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	[REDACTED]
Distributor <i>Vertreiber</i>	[REDACTED]
Product Category <i>Produktart</i>	Greasing and sealing materials: Sealing material and HTB resistant seals for the gas installation (5117)
Product description <i>Produktbezeichnung</i>	Flat sealing material based on graphit for pressure regulators and rotary displacement gas meters, higher thermic chargeable
Model <i>Modell</i>	Grafilit® SP
Test reports <i>Prüfberichte</i>	Laboratory control test: 21-00588-KP04 from 15.03.2023 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)

Date of Expiry / File No. 08.12.2030 / 23-0623-GNV
Ablaufdatum / Aktenzeichen



08.02.2024 Koh A-1/2 *i. A. v. M.*
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Grafilit® SP	Max. operating pressure: 5 bar	

certified Components*zertifizierte Bauteile / Werkstoffe*

Registr. No. Registrier-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NG-5124BL0368	Flat sealing materials on graphit basis	Grafilit SP/Grafilit SP	

Hints of Utilization / Remarks*Verwendungshinweise / Bemerkungen*

Field of application for pressure range ≤ 1 bar: unions and flanges for gas meters and pressure regulators according to DIN 3376-1, DIN 3376-2, DIN 2993 and DIN EN 10242

Field of application for pressure range ≤ 5 bar: flanges for pressure regulators and rotary piston gas meters according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2

